LISTING SERVICE

LISTING No.   7300-1591:101   Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Dr., Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Model FSRZI-A remote zone indicator (Part No. 7990044), Model FSRSI remote system indicator (Part No. 7990043) and Model FSRRM remote relay module (Part No. 7990042). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATINGS: Primary Operating Supply: 21-25 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Edwards, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units. For indoor use only.

NOTE: Formerly 7300-1501:128

09-28-2002 JEW

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**   *Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager